



Building Department
12300 Forest Hill Blvd.
Wellington FL 33414
Phone 561-753-2430 * Wellingtonfl.gov

FLORIDA ENERGY CONSERVATION CODE
Mandatory Duct Inspection Certification for HVAC change-out

For use when part of duct and/or HVAC system has been replaced (Section 101.4.7.1.1 & FS 553.912)

Owner: _____ Contractor: _____
Street Address: _____
Permit Number: _____ Final Inspection Date: _____

I certify that I have inspected the duct work associated with the HVAC unit referenced by the permit listed above and found it complied with the requirements of Section 101.4.7.1.1 as indicated below:

- Where needed, the existing ducts have been sealed using reinforced mastic or code-approved equivalent.
- Ducts are located within conditioned space, (Section 101.4.7.1.1 exception 1)
- The joints or seams are already sealed with fabric and mastic (Section 101.4.7.1.1 exception 2)
- System was tested (see below) and repairs were made as necessary – (Section 101.4.7.1.1 exception 3)

Qualifier: _____ Date: _____

Print Name: _____

Contractor License Number: _____

I certified I have tested the replaced air distribution system(s) reference by the permit listed above at a pressure differential of 25 Pascals (0.10 in. w.c.).

Qualifier: _____ Date: _____

Print Name: _____